

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB0000031
Revision no.:
4

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **A' & 'B' Class divisions fire integrity: - 'B' class division**

with type designation(s)

BIP AH25: B-0 Class Access Hatch

issued to

BIP Industries Co., Ltd. Goseong
Goseong-gun, Korea, Republic of

is found to comply with the Implementing Regulation (EU) 2024/1975 for
Item no. **MED/3.11b (Row 1 of 1)**

according to the following requirements:

SOLAS 74 Reg. II-2/3.4, SOLAS 74 Reg. II-2/9, IMO MSC.1/Circ.1581, IMO MSC/Circ.1120


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2025-09-10**

Expiry date: **2030-09-09**

DNV local unit:
Busan, CMC Korea

Approval Engineer:
Helge Bjørnarå



Notified Body
no.: **0575**



for **DNV AS**

Digitally Signed By:

Christine Mydlak-Röder

Christine Mydlak-Röder
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment signed 17 October 2005, and amended by Decision No 1/2023 dated August 21st, 2023.



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

"BIP AH25: B-0 Class Access Hatch",

a ceiling access hatch composed of a hinged single hatch leaf with hatch frame and locking arrangement. The hatch may be fitted with one push button lock with latch for the smaller hatches and two push button locks with latch for larger hatches. All hatch sizes are fitted with a full length piano hinge.

The hatch leaf comes in two versions, composed either of 1 mm steel plate or 23.5 mm mineral wool (density 140 kg/m³, manufactured by KCC Corporation) covered with 0.6 mm steel plate on both sides.

The hatch frame is made of 1.6 mm steel plate and is fastened to the ceiling panel by overhead screws (Ø4x13).

For further details, see drawing listed under Type Examination documentation.

Application/Limitation

Approved for use as an integrated part of a horizontal fire retarding division of class B-0.

Approved for installation in the tested ceiling BIP C-643 from BIP Industries. Installation in other ceilings may be approved case-by-case. Ceiling has to be approved according to the Marine Equipment Directive and bear the Mark of Conformity.

Maximum hatch size with two push button locks: 590 mm x 590 mm (W x L).

Maximum hatch size with one push button lock: 290 mm x 290 mm (W x L).

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Document No.	Rev.	Title
KBETC-R-25-080-001		Test report dated 2 July 2025 from KBETC, Jeonbuk-do, Korea
F2025-AH25-R0		Drawing dated 17 March 2025 from manufacturer

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG Approval Number if applicable (see first page).