

Certificate Of Fire Approval

This is to certify that the product detailed below will be accepted for compliance with the applicable Lloyd's Register Rules and Regulations and with the International Convention for the Safety of Life at Sea, (SOLAS), 1974, as amended, for use on ships and offshore installations classed with Lloyd's Register, and for use on ships and offshore installations when authorised by contracting governments to issue the relevant certificates, licences, permits etc.

Manufacturer	BIP Industries Co., Ltd.
Address	1817, Jungang-daero, Geumjeong-gu, Busan 46273, Republic of Korea
Type	B-0 Ceiling
Description	Fire Resisting Continuous B-0 Ceiling System – Type: “BIP C-161”
Trade Name	BIP C-161
Specified Standard	IMO Res. MSC.307(88) – (2010 FTP Code) Annex 1 Part 3

This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

The Design Appraisal Document and its supplementary Type Approval Terms and Conditions form part of this Certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached Design Appraisal Document are complied with and the equipment remains satisfactory in service.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Keith Taylor

Team Lead Fire & Safety to Lloyd's Register
EMEA
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

ATTACHMENT TO CERTIFICATE OF FIRE APPROVAL No. LR2275869SF

The undernoted documents have been appraised for compliance with the relevant requirements of International Conventions, and this Design Appraisal Document forms part of the Certificate.

This Certificate supersedes and is a replacement of previous Lloyd's Register Certificate of Fire Approval No: SAS F174003-02.

APPROVAL DOCUMENTATION

1. Fire Insurers Laboratories of Korea (FILK), 69-1 Simseok-Ri, Ganam-Myeon, Yeosu-Gun, Gyeonggi-Do, 469-881, Korea, Test Report No. AK2014-0068R, dated 11 April 2014.

CONDITIONS OF CERTIFICATION

1. "BIP C-161" B-0 Continuous Ceiling System shall comprise of: 0.6mm thick, 600mm wide galvanised steel sheet panels with 15mm thick 'Mineral Wool' insulation (200 kg/m³ density), manufactured by KCC Corporation on the upper side.
2. Total thickness of ceiling panel: 15.6mm.
3. Maximum ceiling panel width: 600mm.
4. Maximum ceiling panel length: 3600mm.
5. Minimum distance between top of ceiling and bottom of deck: 300mm.
6. Adjacent panels shall be joined and connected each other with 'T-Carrier' connection profiles and fitting screws.
7. Ceiling panels shall be suspended from deck by 'P754 Hanger Sets' and 1mm thick x 60mm x 50mm steel 'T-Carrier' connection profiles which also incorporate a 0.6mm steel 'T-Carrier Cover' plate.
8. Composition, application and installation of sub components, including any adhesives, seals and any fire retardants, to be maintained in production and use in accordance with originally tested composition formula and method of application and installation, and manufacturer's instructions.
9. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.
10. The Certificate holder is solely responsible for the products supplied under this Certificate and to ensure that their products are fully compliant with the relevant statutory regulations and Lloyd's Register Class Rules as applicable and designed, manufactured and installed to the same quality and specifications as the prototype tested, including components that are designed and manufactured by third parties.

ATTACHMENT TO CERTIFICATE OF FIRE APPROVAL No. LR2275869SF

PLACE OF PRODUCTION

BIP Industries Co., Ltd.
67 Baedungongdan-gil
Hoehwa-myeon, Goseong-gun
Gyeongnam 52915
Republic of Korea



Keith Taylor
Team Lead, Fire & Safety
Statutory Discipline Team
UK&I Technical Support Office, Marine & Offshore
Lloyd's Register

Supplementary Type Approval Terms and Conditions

This Certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).