

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No: **MEDB00000RY** Revision No:

4

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

That the A & B Class divisions fire integrity: B class divisions.

with type designation(s)
BIP C-562 B-0 Class Continuous Ceiling

Issued to

BIP Industries Co., Ltd. Goseong Goseong-gun, Gyeongsangnam-do, Republic of Korea

is found to comply with the requirements in the following Regulations/Standards: Regulation (EU) 2021/1158,

item No. MED/3.11b. SOLAS 74 as amended, Regulation II-2/3.4 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1581

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until 2026-10-01.

Issued at Høvik on 2021-10-02

DNV local station: Gimhae Station


Approval Engineer: Karolina Kuśmider

0

Notified Body No.: **0575** for **DNV AS**

Sverre Olav Bergli Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005, and amended by Decision No 1/2019 dated February 22nd, 2019.



Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



ab

Form code: MED 201.NOR Revision: 2021-03 www.dnv.com Page 1 of 2



Job Id: **344.1-005087-5**Certificate No: **MEDB00000RY**

Revision No: 4

Product description

"BIP C-562 B-0 Class Continuous Ceiling"

composed of panels suspended below structural deck. The panels consist of 25 mm thick mineral wool (manufactured by KCC Corporation) of density 60 kg/m³, covered with 0.6 mm thick steel sheets or with non-woven fabric and 0.6 mm thick perforated steel (max. Ø1.8 mm, 5% porosity).

Total panel thickness: 25.6 mm

The panels are connected together by grillage main T-bar and cross T-bar and fastened to the deck by slot connection between hanger sets and main T-bar. Panels and T-bars are placed on U-Top profiles which are fitted on the top of the bulkhead.

For further details, see drawings listed under Type Examination documentation below.

Application/Limitation

Approved for use as a horizontal continuous fire retarding division of class B-0.

Maximum panel size: 610 mm x 610 mm (W x L).

Maximum distance from bulkhead to hanger sets along main T-bar: 610 mm.

Maximum distance between hanger sets: 1220 mm. Maximum distance between main T-bars: 610 mm.

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Test report No. AK2015-0688 dated 10 December 2015 from Fire Insurers Laboratory of Korea (FILK), Korea.

Drawing No. F2015-C562-R0 dated 16 September 2015 from the manufacturer.

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, MED Mark of Conformity and USCG approval number if applicable (see first page).

Form code: MED 201.NOR Revision: 2021-03 www.dnv.com Page 2 of 2