

**EC-TYPE EXAMINATION CERTIFICATE (MODULE B)**  Certificate No: MEDB0000030 Revision No:

2

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV GL AS under the authority of the Government of Norway.

## This is to certify:

That the A & B Class divisions fire integrity: B class divisions.

with type designation(s)

BIP C-613: B-0 Class Continuous Ceiling

Issued to

# **BIP Industires Co., Ltd. Goseong** Goseong-gun, Gyeongsangnam-do, Republic of Korea

is found to comply with the requirements in the following Regulations/Standards: Regulation (EU) 2020/1170,

item No. MED/3.11b. SOLAS 74 as amended, Regulation II-2/3.4 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1581

Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until 2025-11-25.

Issued at Høvik on 2020-11-26

DNV GL local station:

**Gimhae Station** 

Approval Engineer:

Karolina Kuśmider




for **DNV GL AS** 

Notified Body No.: **0575** 

Roald Vårheim **Head of Notified Body** 

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005, and amended by Decision No 1/2019 dated February 22nd, 2019. The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity



inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV GL AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled. Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

before being placed on board a vessel to which the amended regulations or standards apply.



Form code: MED 201.NOR Revision: 2020-01 Page 1 of 2

Job Id: **344.1-004804-17** Certificate No: **MEDB0000030** 

Revision No: 2

## **Product description**

"BIP C-613: B-0 Class Continuous Ceiling"

composed of panels suspended below the structural deck. Panels consist of 25 mm thick mineral wool type "MINERAL WOOL 60" (manufactured by KCC, Korea) of 60 kg/m³ density, covered with 0.6 mm thick steel sheet on the exposed side.

The panels are joined together by means of the male and the female sliding arrangement on the panel unexposed side. The ceiling is connected to the deck with P754 Hanger sets and T-carriers.

Total ceiling thickness is 25 mm.

For further details, see the drawings mentioned under Type Examination documentation.

## **Application/Limitation**

Approved for use as a horizontal continuous fire retarding division of class B-0.

Max panel size: 300 mm x 2360 mm (W x L).

Max. distance between T-carriers: 2360 mm Max. distance between Hanger sets: 900 mm

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and use.

#### Type Examination documentation

Test Report No. A2012-0618 dated 23 November 2012 from Fire Insurers Laboratories of Korea (FILK), Korea.

Drawing No. C-613-B0-R0 (7 pages) dated 07 August 2012 from BIP Industries Co., Ltd.

#### **Tests carried out**

Tested according to IMO 2010 FTP Code part 3.

#### Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, MED Mark of Conformity and USCG approval number if applicable (see below).

Form code: MED 201.NOR Revision: 2020-01 www.dnvgl.com Page 2 of 2