Certificate No: TYG00745-FP121

Type Approval Certificate



[Fire Protection Bulkhead]

Initial Approval 10 July 2013

Manufacturer BIP Industries Co., Ltd.

67, Baedungongdan-gil, Hoehwa-myeon, Goseong-gun, Gyeongsangnam-do, Rep.

of Korea

Product Description Brand: BIP W-106SE(6)

- Grade : B-15 Class

See "Appendix 1"

Approval Condition See "Appendix 1"

THIS IS TO CERTIFY that the above-mentioned product has been approved in accordance with the relevant requirement of this Society's Rules and / or of the recognized standards as follows.

Pt.8, Ch.1 of the Rules for Classification of Steel Ships, IMO 2010 FTP Code Part 3 and Res.307(88).

This Certificate is valid until 9 July 2028 Issued at Tongyeong, Korea on 24 April 2023



This certificate is signed electronically in accordance with IMO FAL.5/Circ.39/Rev.2. Validation and authentication of the certificate can be confirmed from "http://e-cert.krs.co.kr" by using the tracking No(ME23016325987) and certificate No.(TYG00745-FP121).



KOREAN REGISTER

M. H. Lee

General Manager of Tongyeong Branch Office

Note: 1. This certificate will be valid subject to complying with the approval conditions described on the certificate and/or on the Rules of this Society.

^{2.} This certificate will be invalid from the expiry date aforementioned unless the extension or renewal has been granted to the applicant or the manufacturer.

^{3.} Any significant modifications or changes in design or construction to the above product without approval from this Society will render this certificate invalid.

^{4.} Should the specified rules, regulations or standards be amended during the validity of this certificate, the product is to be re-approved by this Society in accordance with the requirements as amended.

Appendix 1 Certificate No : TYG00745-FP121

Product Description and/or Approval Condition

Date of Issue: 24 April 2023

- 1. Product Descriptions
- 1) The bulkhead consists of panels having two layers of 22.5 mm thick mineral wool insulation (140 kg/m³, KCC Corporation) with 5mm air gap between insulations, covered with 0.6 mm thick galvanized steel + 0.4 mm thick perforated steel sheet on both sides with adhesive (OCUA 1000RC by Dae Han Polymer Ind. Co. Korea).
- 2) Total thickness of panel: 50 mm
- 3) The panels are connected with a spline joint profile(30 mm x 3 mm) fitted in a M-profile
- 4) Max. panel size : 600 mm x 2480 mm (W x H)
- 2. Approved Drawings : No. W-106SE(6)-R0 (1/6 \sim 6/6)
- 3. Approval Conditions
- 1) This approval is granted on the basis of the test report no. A2012-0931 dated on February 20th, 2013 issued by Fire Insurers Laboratories of Korea(FILK).
- 2) The surface materials, if applied, shall have Type Approval Certificate by the Society.
- 3) In case where the panel is penetrated to incorporate light fixture and similar devices, arrangement shall be made to ensure that the fire resistance is not impaired.
- 4) The product or packing is to be marked with manufacturer name and type designation on a suitable position.
- 5) Any adhesives used in A or B Class divisions should be low flame spread.
- 6) Individual Product Certification is not required. < End of page >

AC-2A (2021.01)