

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB00001DY
Revision no.:
5

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **A' & 'B' Class divisions fire integrity: - 'B' class division**

with type designation(s)

BIP W-302 & BIP W-302E: B-15 Class Bulkheads

issued to

BIP Industries Co., Ltd. Goseong
67 Baedungongdan-gil Goseong-gun 52915 Korea

is found to comply with the Implementing Regulation (EU) 2025/1533 for

Item no. **MED/3.11b** (Row **1 of 1**)

according to the following requirements:

SOLAS 74 Reg. II-2/3.4, SOLAS 74 Reg. II-2/9, IMO MSC.1/Circ.1581, IMO MSC/Circ.1120


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2026-06-17**

Expiry date: **2031-06-16**

DNV local unit:
Busan, CMC Korea

Approval Engineer:
Marta Kropiwnicka



Notified Body
no.: **0575**



for **DNV AS**

Digitally Signed By:

Christine Mydlak-Röder

Christine Mydlak-Röder
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment signed 17 October 2005, and amended by Decision No 1/2023 dated August 21st, 2023.



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

"BIP W-302: B-15 Class Bulkhead"

consists of 48.5 mm thick mineral wool core (from KCC Corporation) with nominal density of 140 kg/m³ faced on the outer sides with 0.6 mm galvanized steel sheets.

"BIP W-302E: B-15 Class Bulkhead"

consists of 47.7 mm thick mineral wool core (from KCC Corporation) with nominal density of 140 kg/m³ and 30 mm wide mineral wool strips on the sides of the panel with nominal density of 240 kg/m³. Panel is faced by means of adhesive with outer 0.6 mm galvanized steel sheets + inner 0.4 mm perforated (max. ϕ =4.0 mm, pitch 8.5 mm) steel sheets. Panel is equipped with internal cable conduit way with dimensions 50 mm x 20 mm (B x W).

Panels thickness is 50 mm.

Panels are connected to each other by removable cap profiles on both panel sides.

For further details see approved drawings listed under Type Examination documentation below.

Application/Limitation

Approved for use as a vertical fire retarding division of class B-15.

Maximum panel size:

- 550 x 2480 mm (W x H) for panels BIP W-302
- 550 x 2480 mm (W x H) for panels BIP W-302E

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation and maintenance.

Type Examination documentation

Document No.	Rev.	Title
F2016-W302E-R0		Drawing dated 13 May 2016 from manufacturer
AK2016-0404		Test report dated 8 July 2016 from Fire Insurers Laboratories of Korea (FILK), Gyeonggi-Do, Korea.
AK2013-0237		Test report dated 4 November 2013 from FILK, Gyeonggi-Do, Korea.

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the Mark of Conformity and USCG approval number if applicable (see first page).